
CDBG Water Main Project

7 Blocks

Maple & York → Hwy

- 4 main breaks
- Original 1880

13 Blocks

Mill & Beaver → water tower past Oberlin Inn

- Excessive sediment build-up
- Known leaks but because of build-up no loss of water supply
- No main breaks
- Original 1880 pipe
- Some road demo for replacement

6 Blocks

East → Commercial → N. to Adams 3 blocks north of

Ash

- 1 main break (Washington)
 - 3 main breaks at Ash & East intersection
 - Potential for road demo and replacement
-

CDGB-All Water Main Recommendations

